

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214745
Address: 130 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Friday, January 21, 2022

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	1-21-22 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -MAINTAIN SILT FENCE AT FRONT OF LOT, GRAVEL FILTER, CLEAN DEBRIS FROM STREET, CLEAN DEBRIS FROM STORM INLET
---	----------------------------	---

Comments: