



March 4, 2021

ABI  
1271 NE Delta School Rd  
Lee's Summit, MO 64064

**RE: Subgrade Inspection for Lot # 95 Woodside Ridge – 202 NW Ambershame  
Lee's Summit, MO 64081 – Permit # 2020-4979**

On March 3, 2021, a special inspection was performed by Residential Engineering Services, LLC (R.E.S.) at the above referenced property. The purpose of this inspection was to verify proper application and instillation of AB3 per subgrade letter recommendations written on February 4.

- RES verified that the subgrade soils are a competent clay soil with no apparent compaction or moisture issues.
- Entire footprint was backfilled in 8" lifts with compacted AB3 to reach proposed footing elevation.
- Permit plan footing is approved to be poured on top of compacted AB3 mat.

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

A handwritten signature in blue ink, appearing to read 'B. Huxol', is written over a light blue horizontal line.

Bradley Huxol, PE

