

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211762
Address: 4724 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, January 24, 2022

Corrective Action Required:

1	Misc	-Move smoke alarm outside master bedroom higher **Provide smoke alarm installation doc -Provide min 12" horizontal clearance from light to basement closet storage space **Min 12" horizontal clearance is required for surface-mounted LED luminaire. Storage space is defined as a space on the left&right and rear sides of closet, 12" out from walls extending from floor to ceiling and 24" from wall from floor to clothes hanger height.
---	------	---

Comments: