

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214970
Address: 940 NW PRYOR RD, Unit:M, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Monday, January 24, 2022

Informational:	
1 Misc	- TOP OUT SHEETROCK WALL BETWEEN DINING & KITCHEN -
Corrective Action Required:	
2 Miscellaneous	Provide mid point support vertical DWV 2" & smaller
Correction	Provide boca plates mens restroom

Comments: