

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Passed	Monday, January 24, 2022

Corrective Action Required:

1	Misc	WELDS APPROVED FOR 1ST LAYER WRAP 1ST LAYER WRAP APPROVED FOR 2ND LAYER 2ND LAYER WRAP APPROVED ALL 4 GREASE DUCTS
---	------	--

Comments: