CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204351

Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Monday, January 24,

Residential 2022

Corrective Action Required:

1 Miscellaneous NO FURTHER INSPECTIONS UNTIL PLUMBER ADDED TO PERMIT Correction Mitchell Schwarz 1/24/22

- Nail exterior sheeting per code/plans, back

windows

- Through bolts on I- beam not tightened
- -fireblock furr outs for in garage
- Land all electrical wiring upstairs master bedroom
- Address over bored joist living room
- Address over bored studs right of fire place
- Provide 2 1200 lb straps bay window per plan
- Complete though bolts above formal dining (tighten)
- Address over bored joist front closet
- fireblock Fur out pipes in front closet
- -repair broken window back of house
- Provide stud pack at basement stairs per plan

Comments: