CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196

Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Water Line - Construction Inspection		Adam Nacke	Partial	Monday, January 24, 2022
Informational:				
1	Misc	12-8-21 AN Holthouse has began installing the water main on the 7th plat. They have got around 80ft in today but are missing fitting and can't proceed with out them 12-9-21 AN crew installed 380 ft of water main today. On ne feather In 12-10-21 AN Holthouse has two crews at park ridge 7th and 8th installing water mains. All products appear to be LS approved products. Tracer wire, water identification tape and plastic around fittings are being installed.		
Informational:				
2	Miscellaneous Correction	were 100% wrapped in the Some of the joints/fittings	e crew to make sure that ale plastic. Is the plastic was just layed of the plastic was just layed of the 7th ale	over top of them.
Informational:				
3	Misc		w in stalling water main on vith some major deflection	

12-15-21 AN crew poured some of the thrust blocks but not all of them yet

install the 2 11 1/4 bends according to the plans. I informed the crew and

they did fix it.. two pics attached (pipe deflection before/after)

12-15-21 the isolation valves for the fire hydrants on average were about 6++ ft form the hydrants and need to min 20" max 42". Holthouse is fixing the issue.

Informational:

4 Misc

1-24-22 AN Holthouse did two water main tie-ins. 1 on ne hideaway dr and 1 on ne park springs ter. Water was out for about 6hrs

Comments: