

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211547  
Address: 3073 NW THOREAU LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, January 25, 2022

Informational:

1	Miscellaneous Correction	7-27-21 Portal Frame Inspection: OK to cover exterior at PFH
		*rear covered patio truss ok. front ok

Corrective Action Required:

2	Misc	-terminate Romex north office exterior wall - provide eng fix on truss over garage supported by blocking. -Provide corrections for cut joist in basement behind furnace at DWV
---	------	--

Comments: