

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216024
Address: 601 NE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Michael Harkins	Failed	Tuesday, January 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE GAUGE WITH MINIMUM 10 PSI FOR 15 MIN FOR GAS TEST PAINT NEW GAS LINES
---	--------------------------	--

Comments: