

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRESRES20204862
Address: 330 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, January 25, 2022

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none">- Label non GFCI outlet in garage- Provide spark rings outlets kitchen counter- Gfci outlet over bar counter will not reset- Outlets at bar need spark rings- Label non GFCI outlets in basement- Smoke detector by furnace covered and beeping- Provide 6" clearance grade to siding garage by front door sidewalk- Provide 2 x 1/2" through bolts on all post to beam connections- complete irrigation permit and submit backflow cert.
---	--------------------------	---

Comments: