

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210623
Address: 2118 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, January 26, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE GAUGE WITH MINIMUM 10 PSI FOR 15 MINUTES
---	--------------------------	--------------------------------------------------

Comments: