

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210623
Address: 2118 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|-----------|-----------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Not Ready | Wednesday, January 26, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | Provide CS-PF exterior bracing dining room per plan (2018 IRC R602.10) Install missing windows dining room Nail exterior wall sheathing per plan (2018 IRC table 602.3 (3)) Okay to insulate |
|---|--------------------------|--|

Comments: