

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201466
Address: 4060 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Adam Nacke	Failed	Wednesday, January 26, 2022

Partial Correction:

1	Misc	I will talk with contractor to ensure streets are cleaned up at the end of work day. the forecast of rainy weather will require we stay abreast of the need to frequently clean the streets connected to the site.
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	1-26-22 AN 1. there is no erosion control in place on the lots being built .. 2. silt fence that is in place needs to be repaired also 3. street needs to be cleaned 4. It front of storm boxes need to be cleaned 5. Trash and old pipes in the field need cleaned up. WE WILL PUT A STOP WORK ORDER ON ALL LOTS IF NOT TAKEN CARE OF ASAP
---	--------------------------	---

Comments: