

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210252
Address: 138 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, January 26, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 2/28/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Wednesday, January 26, 2022

Corrective Action Required:

3	Misc	-final grade and sod -splash blocks and sump pump discharge to be 36" from foundation -check water meter at time of final grade and sod -2 1/2" through bolts at all post to beam connections
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------