

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212317  
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, January 26, 2022

Corrective Action Required:

2	Misc	-Address missing roof boots -Complete vent master bathroom -Fire block soffit at stairs/foyer - Provide LIB bedroom 2 closet -Provide attic access -Tighten all anchor bolts garage -Solid block sheet break foyer -Fire rate foyer wall, 9'8" to adjacent house -Nail exterior sheeting per code -Provide lateral support for trusses per plans
---	------	---

Comments: