CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20215409 Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Thursday, January 27, 2022
Corrective Action Required: 1 Misc	-Provide city approved, stamped plans for inspection -Seal all through floor penetrations with appropriate fire stopping matearial -Repair all fireproofing to structural members		

-Provide bocca plates at bottom track at dwv

-Midpoint strap at 2" dwv in bathroom

-Install missing track at bathroom

-Have engineer address holes in structural slab

Comments: