

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212708
Address: 4705 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, January 27, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED, EROSION CONTROL NOT IN COMPLIANCE
		-EROSION CONTROL REQUIRED AT FRONT OF LOT
		-MAINTAIN GRAVEL FILTER ON DRIVE, 6" LIFT REQUIRED TO PREVENT MUD TRACKING

Comments: