

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211818
Address: 1528 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, January 27, 2022

Corrective Action Required:

2	Misc	-furr downs not complete 1st and 2nd floor -fire stoping though out -electrical not in complete -plumbing supports -lib's not to code -fire places not install -csst not supported properly -due to to many items not in compliance inspection not ready
---	------	---

Comments: