CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211621

Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Thursday, January 27,

Residential 2022

Corrective Action Required:

1 Misc NO FURTHER INSPECTION TO BE PERFORMED UNTIL EROSION CONTROL IS IN

PLACE AND IN COMPLIANCE

- -final grade and sod
- -check water meter at time of final grade and sod.
- -Handrail required at garage stairs -can not check outlets in garage
- -secondary locking device on sliding back door
- -handrail to basement required
- -hardware on basement sliding back door
- -electrical in unfinished area not landed next to water heater
- -lock out for hot water heater breaker
- -seal top of meter can, lights, and all other exterior penetrations
- -back patio lighting must be of the sealed type
- -(2) 1/2" through bolts required at deck post to beam connections

Comments: