



PLAN REVIEW CONDITIONS

January 27, 2022

SUMMIT WOODS SPE LLC
1 E WASHINGTON ST STE 300
PHOENIX, AZ 85004

Permit No: PRCOM20220280
Project Title: 1752 NW Chipman White Box
Project Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081
Parcel Number: 51700031300000000
Location: CHIPMAN HWY 50--- LOT 12
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: MERCANTILE
Description: Owner RED Dev work for separation of existing space into 2 separate spaces.

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Pending

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required- Provide plans for any modification to alarm notification and initiating appliances.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Action required- Adjust door numbering Address) . Verified at inspection.

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required- Submit plans for sprinkler modification to the spaces to maintain coverage.

4. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816) 969-1300 to schedule testing, preferably before regular business hours.

5. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action required- Provide a minimum of one 2A:10B:C fire extinguisher in each of the spaces. Verified at inspection.

Building Plan Review

Reviewed By: Joe Frogge

Pending

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.