

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211706
Address: 2349 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, January 28, 2022

Corrective Action Required:

1	Misc	-address studs Board for dwv in master bathroom load bearing wall -revise plans to show hip extending over bearing wall -provide mechanical strap where top plate does not intersect with other walls back wall see great room wall -seal penetrations in vertical to horizontal fire blocking
---	------	---

Comments: