



WATER UTILITIES LEE'S SUMMIT

220 SE GREEN ST, LEE'S SUMMIT, MO 64064
PHONE: (816) 969-1930 FAX: (816) 969-1935
EMAIL: backflow@cityofls.net WEB: lswater.net

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER TRUMARK HOME							
SERVICE ADDRESS 330 NW AMBERSHAM DR							
LOCATION OF BACKFLOW ASSEMBLY ON PROPERTY BASEMENT UNDER PORCH							
DATE OF TEST 9-17-2021		TIME 10:30		SUPPLY PRESSURE 75 LBS		AIR GAP (2 X SUPPLY DIAMETER) SUPPLY 1/2 IN. GAP 1/2 IN. <input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
TYPE OF ASSEMBLY <input checked="" type="checkbox"/> DC <input type="checkbox"/> RP <input type="checkbox"/> DCCDA (DETECTOR) <input type="checkbox"/> RPDA (DETECTOR) <input type="checkbox"/> PVB* (SEE BOTTOM OF FORM)		MANUFACTURER FEBCO		MODEL 850		SIZE 3/4"	
HEIGHT OFF FLOOR 2' FT 0 IN		PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		SUPPLY SOURCE: <input checked="" type="checkbox"/> PUBLIC POTABLE WATER <input type="checkbox"/> NON-POTABLE WATER (e.g., LAKE) <input type="checkbox"/> BOTH		NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
INITIAL TEST REDUCED PRESSURE PRINCIPLE ASSEMBLY: RELIEF VALVE OPENED AT _____ PSID (2 PSID or more) 2ND CHECK held backpressure NO. 2 SHUTOFF VALVE leak tight 1ST CHECK held in direction of flow _____ PSID (5 PSID or more) DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more) NOTE: Failure of any of the above items, requires repair.				FINAL TEST AFTER REPAIR REDUCED PRESSURE PRINCIPLE ASSEMBLY: RELIEF VALVE OPENED AT _____ PSID (2 PSID or more) 2ND CHECK held backpressure NO. 2 SHUTOFF VALVE leak tight 1ST CHECK held in direction of flow _____ PSID (5 PSID or more) DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more) NOTE: Failure of any of the above items, requires repair.			
INITIAL TEST DOUBLE CHECK VAVLE ASSEMBLY: 1ST CHECK held in direction of flow 2.3 PSID (1 PSID or more) 2ND CHECK held backpressure 2ND CHECK held in direction of flow 2.4 PSID (1 PSID or more) NO. 2 SHUTOFF VALVE leak tight NOTE: Failure of any of the above items, requires repair.				FINAL TEST AFTER REPAIR DOUBLE CHECK VAVLE ASSEMBLY: 1ST CHECK held in direction of flow _____ PSID (1 PSID or more) 2ND CHECK held backpressure 2ND CHECK held in direction of flow _____ PSID (1 PSID or more) NO. 2 SHUTOFF VALVE leak tight NOTE: Failure of any of the above items, requires repair.			
APPLICATION: <input type="checkbox"/> COMMERCIAL <input checked="" type="checkbox"/> IRRIGATION <input type="checkbox"/> FIRE LINE <input type="checkbox"/> FIRE LINE BY-PASS **METER # _____ **METER READ _____ <input type="checkbox"/> POINT OF USE		COMMENTS INSTALLED BACK FLOW TESTED WORKING CORRECTLY					
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE							
TESTED BY (PRINT) DANIEL J BOSTER		(SIGNATURE) 		REPAIRED BY (PRINT)		(SIGNATURE)	
COMPANY THE VALLEY LAWN & LANDSCAPE		FINAL TEST BY (PRINT)		(SIGNATURE)		DATE OF FINAL TEST	
MISSOURI CERTIFICATION NUMBER 34-11206		EXPIRATION DATE 9-30-2022		OWNER OR OWNER'S REPRESENTATIVE		DATE	
* If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations. New PVB installations or replacements are not permitted. ** METER # and METER READ for the fire line by-pass meter on detector assemblies are required. Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.							