

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211220
Address: 2125 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, January 31, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide H2.5 / truss lock trusses above fire place Strap top plate above front door no overlap Fire block dryer vent at furr out laundry Provide nuts, washers & tighten anchor bolts basement Provide solid security blocking patio door Provide double 2 x 10 joist at deck per plan Seal upward penetration top plate above door a bottom of stairs
---	--------------------------	--

Comments: