

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20201058
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Backflow Preventer and Vault	John Jackson	Passed	Tuesday, January 18, 2022

Informational:
1 Misc 8/4/20 Monday Contractor (SDI) is installing Backflow Preventer as-built will reflect the change.
They were unable to make new lid fit the old Backflow Preventer box so replacement was the sensible and was actually the original plan. I will continue to monitor progress throughout the day.

Comments: