

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20203583  
**Address:** 2304 SW CHASE CIR, LEES SUMMIT, MO 64082  
**Inspected On:** Wednesday, January 12, 2022  
**Inspected By:** Mitchell Schwarz  
**Expiration Date:** 2/11/2022 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Temporary C of O	Wednesday, January 12, 2022

**Corrective Action Required:**

1	Misc	TCO UNTIL 11/29/21 -deck beams must comply with code section R507.5.2 -sod/final grade -splash blocks and sump pump discharge 36" from foundation -install deck fire place
---	------	--