



OXFORD ARCHITECTURE

2934 Sidco Drive, Suite 120
Nashville, TN 37204
(P) 615.256.3455
(F) 615.256.3404

Revision 1

TO: General Contractor, Owner

FROM: Brad Matuzak

DATE: 01.30.2022

SUBJECT: Caliber Collision - Lees Summit, MO

The following project update(s) are from plan review comments, civil coordination, and building coordination for your information.
In the event that further clarification is required, please contact me at brad@oxfordarchitecture.com or by phone at 615.256.3455 x 15.

Revisions to drawings:

COVER

- Added current revision information to sheet.

A0.1

- Added Plan Review Notes
- Added FP1.0 to Sheet Index
- Updated Sheet Index to Revision 1

CS0.1

- Added Fire Riser room to Occupant Load Calculations

A1.0

- Added keynote for floor sink @ Fire Riser Room
- Added sheet note for CMU control joints under General Notes
- Added Fire Riser room and Door 114
- Added roof access to Electrical Room

A1.1

- Added roof access hatch

A1.2

- Added roof access hatch

A2.0

- Added control joint locations
- Added door for Fire Riser room
- Added keynote for FDC

A2.1

- Updated Shop wall elevation

A3.0

- Added ladder elevation at Electrical Room
- Added ladder/hatch details
- Added general OSHA standard notes for hatch guardrail

A4.0

- Updated keynotes in both floor plan and ceiling plan
- Added Fire Riser Room 114
- Added roof access hatch in Electrical Room

A6.0

- Added Door 114 to Door Schedule

P1.0

- Added RPBP, TP-2, FS and WCO to Riser Room 114
- Moved Note 24 to Note 8
- Added to Note 5

P2.0

- Added RPBP and TP-2 to Plumbing Fixture Schedule

P3.0

- Added Reduced Pressure Backflow Preventer Detail to Sheet
- Updated Waste & Vent Riser and Domestic Water Riser to reflect changes

FP1.0

- Added Fire Riser, Fire Dept. Connection and Primary Location of Fire Protection Water Entry to Fire Riser Room 114
- Changed Sprinkler Head Locations in Lobby 100
- Changed Minimum Number of Portable Fire Extinguishers to 9, Note 2 under General notes

END OF REVISION 1