

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214830  
Address: 419 SW WARD RD, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Tuesday, February 01, 2022

Corrective Action Required:

1 Misc

PHASE 1 UNIT B SIDE ONLY: OK EXCEPT AS NOTED

-SUPPORT NM AT KITCHEN AND MECHANICAL AND PATCH BACK SHEET ROCK AT MECHANICAL I JOISTS.

**Comments:**