CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211218

Address: 127 NW JOSHUA DR, LEES SUMMIT, MO 64081

Inspected On: Tuesday, February 01, 2022

Inspected By: Michael Harkins Expiration Date: 04/05/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Occupancy Inspection - Michael Harkins Temporary C of O Tuesday, February

Codes Residential 01, 2022

Corrective Action Required:

1 Miscellaneous Provide sod

Correction Provide splash blocks

Sump shall discharge 36" from foundation Seal top of ac disconnect & gas line at meter

SUBMIT AS BUILT PLOT PLAN PER MASTER DRAINAGE PLAN