## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRSUBD20211958Address:2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection	Tom Taylor	Passed	Tuesday, February 01, 2022
Informational: 1 Misc	11/5/2021 Contractor raised existing manholes MH 1-3, MH 1-4, MH 1-5, MH 1-6 and MH 1-7.		
		ntractor, Redford Construct hitary pipe(8-inch SDR 26 PV	•
	On Tuesday 12/07/2021 C 8-inch SDR 26 sanitary pip	ontractor, Redford Consruc be and MH 1-1	tion installed 171 LF of
	On 12.08.2021 Wednesday Contractor installed MH 1-2 was installed and 224 LF of sanitary pipe.		
	On 12.09.2021 Thursday (	Contractor installed 11 later	als and MH 1-3
	On 12.10.2021 Friday Contractor is backfilling the sanitary lines 2 and 3		
	•	ontractor installed 3 service 1-4. Construction began on	
	12.16.2021 Thursday Cont three laterals.	ractor, Redford Constructio	n installed MH 2-1 and

Informational:	On Wednesday, 12-22-2021. Redford resumes sewer laterals for line 2. Redford installed laterals north and south of the main sewer from MH 1-3, 2-1 and 2-3. Contractor Redford wets project site to keep down the dust down and back fills some of the laterals on the main.
2 Misc	On Monday, 12-20-2021. Redford Excavating resumed Sanitary Sewer installation. Contractor layer approx 80 LF of 8" Sewer pipe and placed (1) lateral for lot 112. Contractor hit rock and it has slowed installation of sewer.
	On Tuesday, 12-21-2021. Contractor resumed Sanitary Installation for line 2. Approx 100 LF of 8" pipe was placed and (3) laterals where installed as well. Contractor is watering down fill materials to back fill with.
	On Thursday, 12-23-2021. Redford Excavation resumed Sanitary Sewer back filling for laterals previously placed. Contractor watered down Shell back fill for proper moisture compaction. Contractor also reinstalled (1) Man Hole riser and lid that had been disturbed.
Informational: 3 Misc	On Monday, 1-3-2022. Redford Excavating resumed Sanitary Sewer installation.
	I, Tom Taylor was off on Christmas Holiday's from 12-24-2021 to Monday the 12-28-2021. On Tuesday I was not in due to what I thought was a chest cold. On Wednesday, 12-29- 2021. I returned to work . The contractor worked to install Line 4. The contractor installed MH 4-1 and approx 120 LF of 8" PVC pipe. In Late afternoon I was asked to not return to work for the next day until I could show a negative Covid test result. On Thursday I received a COVID test and was found to have contracted the virus. The contractor completed line #4 while I was out including all laterals and back filled.
Informational: 4 Misc	On Wednesday, 1-05-2021, I returned with a negative test result. The contractor Redford had began installation of line #1. Contractor connected to the existing MH #1-7 and installed 171 LF of 8" pvc pipe. Contractor also installed MH 1 - 1 and approx 120 LF of 8" pvc sewer pipe.
	On Monday, 1-3-2022. Redford Excavating resumed Sanitary Sewer installation.
Informational: 5 Misc	On Monday 1.10.2021 contractor is installing Line 4 and 5 laterals.
	On Monday, 1-3-2022. Redford Excavating resumed Sanitary Sewer installation.
	On Monday 1.10.2021 contractor is installing Line 4 and 5 laterals.
	On Tuesday 1.11.2021 Contractor is installing sanitary sewer line 4 and laterals

Informa	tional:	
6	Misc	On Monday, 1-3-2022. Redford Excavating resumed Sanitary Sewer installation.
		On Monday 1.10.2022 contractor is installing Line 4 and 5 laterals.
		On Tuesday 1.11.2022 Contractor is installing sanitary sewer line 4 and laterals
		On Wednesday 1.12.2022 Contractor installed MH 4-2 and set 2 laterals. Contractor back filled sanitary Line 4.

## Comments: