

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211621  
Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, February 02, 2022

Corrective Action Required:

1	Misc	-sod -check water meter and siding from grade at time of final grade and sod. -hardware on basement sliding back door -electrical in unfinished area not landed next to water heater -lock out for hot water heater breaker -seal top of meter can, lights, and all other exterior penetrations -back patio lighting must be of the sealed type -(2) 1/2" through bolts required at deck post to beam connections
---	------	--

**Comments:**