

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212836
Address: 3217 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, February 02, 2022

Corrective Action Required:

1	Misc	-fireblock deadspace front bedroom entry -all truss hangers per plans (tjc37, thx 57) -all truss lateral bracing per plans -bocca protection plate at furred down basement bedroom closet
---	------	--

Comments: