

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211943
Address: 2358 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, February 03, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Toe nail joist to top plate-add stud to support double joist (garage entry)-seal all top and bottom plate penetrations though out-fire block above fridge-fire block above great room for dwv-complete gas line bonding-fire block furr down ends in basement-fire block vertically every 10' horizontally-double joist hanger (2) basement-fire block around egress window-complete upstairs laundry double wall-sold block sheathing breaks at back wall 2nd floor
---	------	--

Comments: