

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213404
Address: 2118 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Patrick Schonfeldt	Failed	Thursday, February 03, 2022

Corrective Action Required:

1	Misc	-REPLACE ACORN STYLE CLAMP FOR GEC TO UFER TO ONE THAT IS RATED FOR REBAR CONNECTION SEPARATION
---	------	---

Comments: