

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211621
Address: 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082
Inspected On: Friday, February 04, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 4/4/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Friday, February 04, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 4/4/22 -sod -check water meter and siding from grade at time of final grade and sod. -seal top of meter can, lights, and all other exterior penetrations -(2) 1/2" through bolts required at deck post to beam connections
---	------	--