

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210875
Address: 3057 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Shawn Hoffman	Failed	Friday, February 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	- provide correct bonding clamp for copper wire - pressure test passed
---	--------------------------	---

Comments: