

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211236
Address: 2163 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, February 04, 2022

Corrective Action Required:

1 Misc

Corrective Action Required:

2 Misc

- Pay all fees due before occupancy
- Sidewalk inspection pending
- Illuminated address required for occupancy
- Maintain erosion control until sod is in place
- Place range on anti tip device
- Secure post at mid stair landing
- Secure handrail to basement
- Provide ladder at egress well
- Garage door must self close and latch
- Set attic access cover at garage
- Obtain lawn irrigation permit and backflow certification
- Final grade, sod, splash blocks, sump extension

Comments: