

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20210022  
**Address:** 333 NW AMBERSHAM DR, LEES SUMMIT, MO 64081  
**Inspected On:** Friday, February 04, 2022  
**Inspected By:** Mitchell Schwarz  
**Expiration Date:** 4/4/2022 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Temporary C of O	Friday, February 04, 2022

**Corrective Action Required:**

1	Misc	TCO UNTIL 4/4/22 -complete final grade and sod -check water meter and siding from ground at time of sod -splash blocks and sump pump discharge to extend 36" from foundation -seal top of meter can, A/c disconnect & all other exterior penetrations
---	------	---