

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212317  
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:      | Outcome:  | Date:                     |
|---|-----------------|-----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Michael Harkins | Not Ready | Friday, February 04, 2022 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -Fire rate foyer wall, 9'8" to adjacent house<br>( per 2018 IRC section 302 / table R302.1 (1)<br>pyroguard not osb |
|   |      | -Nail exterior sheeting per code<br>( rear wall near fireplace )  |

**Comments:**