

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204351  
Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, February 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none"><li>- Nail exterior sheeting per code/plans, back windows cs-pf</li><li>- fireblock furr outs for in garage</li><li>- Address over bored joist living room</li><li>- Address over bored studs right of fire place</li><li>- Provide 2 1200 lb straps bay window per plan (cs-pf)</li><li>- Address over bored joist front closet</li><li>- fireblock Fur out pipes in front closet</li></ul>
---	--------------------------	--

**Comments:**