

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214631
Address: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Ronald Paynter	Partial	Friday, February 04, 2022

Informational:

1 Misc

Met Dakota from ESS on site to pull 2nd Bac T samples. Dakota said there was too much snow over the water main, so we decided to wait until Monday to pull the samples. RP 2-4-22

On 2.7.2022 Monday ESS pulled 2nd water sample for coliform testing. Samples taken to Blue Valley Labs.

Comments: