CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSITE20211246Address:1010 NW PRYOR RD, LEES SUMMIT, MO 640811000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Abandonment	Ronald Paynter	Passed	Wednesday, February 09, 2022

Corrective	e Action Required:	
1	Misc	Earl from ESS removed existing manhole and sanitary pipe to correct
		abandonment location. Plans called for a cap, but explained that our spec
		calls for a plug. They plan on correcting this issue tomorrow. RP 11-16-21
Informati	onal:	
2	Misc	The sanitary line was abandoned correctly. RP 11-17-21

Comments: