

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081  
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary - Material Verification</b>	Ronald Paynter	Passed	Wednesday, February 09, 2022

Informational:

1	Misc	Sanitary materials onsite include: 6", 8", 10" SDR26 pipe, wye fittings, bends and max adapters for the wye connections. Still waiting on all manhole components(barrels, cones, adjustment risers, rings and lids). 11/9 ES.
---	------	---

Informational:

2	Misc	Sanitary Manhole base, barrel, and cone sections were delivered, manufactured by Barbour with correct steps and A-Locks. Still waiting for castings and lids. 11/17 ES
---	------	--

Informational:

3	Misc	Correct castings and lid were delivered. RP 11-19-21
---	------	--

**Comments:**