

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220023  
Address: 2939 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                        |
|-------------------------------------------|------------------|----------|------------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Wednesday, February 09, 2022 |

Corrective Action Required:

|   |      |                                                                                                                             |
|---|------|-----------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -unface insulation for fireblocking<br>-seal upward penetrations<br>-seal penetrations in every 10' horizontal fireblocking |
|---|------|-----------------------------------------------------------------------------------------------------------------------------|

**Comments:**