

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210729
Address: 2159 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, February 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	OK to insualte -- do not cover inspection items. - over drilled joist #3 joist west of panel for home run of electrical-
---	--------------------------	---

Comments: