CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213403

Address: 2117 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Patrick Schonfeldt Failed Wednesday, February

Residential 09, 2022

Corrective Action Required:

1 Misc -Maintain gravel filter on drive

-repair subfloor at kitchen island and fireblock penetrations

-solid block sheathing breaks at front entry -install flashing boots at roof penetrations

-fireblock tub traps

-(4) 2x4 stud pack at great room girder truss bearing per plans

-approved truss drawings do not match trusses on site, revise and resubmit

for approval

-add circuit for hot water heater

-land wire to metal box at service panel-nail sheathing at garage PFH per code

Comments: