

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Thursday, February 10, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	2 EAST EXTERIOR CANOPIES-OK NORTH EXTERIOR CANOPY-OK -SOFFITS AT: CLEAR STORY A100, B100A -HARD LIDS AT A213, B114, 121A, B113, C100A ,,B115,B117,C101A,C10,C10A,C129,C127,C121,C115D,C102-C104, C208, C214, C20 BUILDING A: A111,A112,A113, A100A,A100C,,A13,A110B,A101, A103, A104, A105, A106 A108,A108A,A110,A110A,117A,117B,118,118B A202, 203, 204, 205, 207, 208, 209, 210,21,200A,23,24,220A BUILDING B: 101-103, 105-108, 110, 110A, 111,112, 117,118, 121, 121C, 122, 201-206, 208, 209, 211, 212, 214A, 215, 216, 216A, CORRIDORS EXCEPT AT B10 AND AT RATED ASSEMBLIES **B113,B115, B121C, B121D, B122, B121, B121B, B120, B119 B212, B201, B203, B204-OK FOR BORDERS ONLY BUILDING C: 101,101A,106-109, 111-113, 119, 120, 122-126, 128-131, 201-204, 211, 212, ,115-115C, 217A-217D, 219-219C, ALL CORRIDORS EXCEPT AT RATED
---	----------------------------------	---

ASSEMBLIES

**C102, C104, C115A, C115B, C115C ,C117, C118, C119,C210, C206, C207 OC216, C216B,OK FOR BORDERS ONLY

AREA D

- 1/27/22 HARD LIDS: D103 MEDIA CENTER, D101 A la carte counter, G108D -

AREA G: 102,103,107,108,108B,108F OK FOR BORDERS ONLY

Corrective Action Required:

2

Misc

A218, A218A- OPEN J BOXES

B210- OPEN J BOX

B214- OPEN J BOX, EXHAUST HOOD, MISSING (2) TIE WIRES AT MAIN

C206,207- COMPLETE FIRE RATED ASSEMBLY AT SEPARATION WALL

-SEAL PENETRATIONS, STENCILS AT FIRE SEPARATION WALLS THROUGHOUT CORRIDORS

-COMPLETE RATED ASSEMBLIES AT PENETRATIONS, TOP AND BOTTOM AND STENCILS AT VESTIBULES, CORRIDORS, AND ELEVATOR

Comments: