

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216422  
Address: 3550 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, February 10, 2022

Corrective Action Required:

1	Misc	-SWAP LAV AND TUB IN BASEMENT BATH GROUP, NOT MORE THAN ONE WET VENTED FIXTURE DRAIN SHALL DISCHARGE UPSTREAM OF THE DRY VENTED FIXTURE DRAIN CONNECTION, P3108.2.2 HORIZONTAL WET VENT
---	------	---

**Comments:**