

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220013
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, February 10, 2022

Corrective Action Required:

1	Misc	FOOTING POURED WITHOUT INSPECTION, THIRD PARTY INSPECTION REPORT REQUIRED TO BE UPLOADED TO PERMIT WITHIN 48 HOURS OF INSPECTION
---	------	--

Comments: