

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211821
Address: 1904 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, February 11, 2022

Corrective Action Required:

1	Misc	-Address -Final grade, sod, downspout and sump pump extension -Install ladder at window well -Install sewer tracer wire port -Garage door not self-closing -Install backflow preventer at hose bibb -Secure water service pex line
---	------	--

Comments: