


February 11, 2022

Summit Homes
 120 SE 30th St.
 Lee's Summit, MO 64082

RE: Revision to main floor framing for relocation of doorway in the dining room at Lot # 141 Hawthorne Ridge – 3121 SW Arboridge Dr. Lee's Summit, MO 64081 – Permit # PPRS20213320

Revision to main floor framing shall be as follows:

- A dropped header shall be installed in lieu of a load bearing wall to allow for the framing of the newly located dining doorway.
- (2) #2 2 x 10 dropped shall span approximately 5.75 ft with with 14 ft tributary width with standard floor loads of approximately 700 plf. End supports shall be (1) #2 2x4 king stud and (2) 2x4 jack studs at dining room header.



Sincerely,



Bradley Huxol, PE

